

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 908

Dated: 22/5/24

It is certified that an inspection team headed byCHAMPALAL BERYA.....

(Name of Officers with designation) fromA.E.N. BHOPALGARH.....

(Name of Department/ Office) inspected the St. Hrit's vidyashram Hiradesar road
Bhopalgash(Name & Address of the school) on 22-5-2024.....(date of inspection) and found that the
St. Hrit's vidyashram.....(Name of school) has safe drinking water
facilities for the students and members of staff of the institution and is maintaining the hygienic
sanitation condition in the school building & the campus as per norms prescribed by the Central/
State/ U.T. Govt.

The above is valid for a period of

Signature with Seal: 

Name

सहायक अभियन्ता

Designation

जन स्वा. अभि. विभाग

उपखण्ड-भोपालगढ़

DDO कोड-1237

Name & Address of the Office / Department :

To

St. Hrit's vidyashram

Hiradesar road Bhopalgash, Bhopalgash Dist. Jodhpur
Rajasthan

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



Office of the Superintending Chemist
Public Health Engineering Department, Rajasthan
Regional Laboratory, Jodhpur

Report of The Chemical Examination of Water

No.Lab./Tech.(chem)/2024-25/ 253

Date: 27-06-2024

To
St. Hrit's Vidyashram
Hiradesar Road, Bhopalgarh, Jodhpur

**SAMPLE WAS NOT COLLECTED
BY THE LABORATORY**

Not for Legal Purpose

Reference No. : Your Application on Dated: 20-06-2024

District : Jodhpur

Date of Receipt : 24-06-2024

Sample Taker : Sh. Ramprakash

Source	Permissible Value as per B.I.S : 10500/2012		RO Water
Location			School Campus
Block	Desirable Limit	Permissible limit in absence of alternate Source	----
Village/Town			----
Gram Panchayat			----
Date of Collection			20-06-2024
Date of Examination			27-06-2024
Sample No.			PC-32

Note:- All results except pH are in mg/L

	6.5 to 8.5	No relaxation	7.5
pH	6.5 to 8.5	No relaxation	7.5
Turbidity(NTU)	1	5	0.0
Colour	5	15	0.0
Odour	Agreeable	Agreeable	Unbjectionable
Temperature	----	----	----
Total Alkalinity	200	600	20
Total Hardness (as CaCO ₃)	200	600	10
Calcium (as Ca)	75	200	6
Magnesium (as Mg)	30	100	4
Chloride(as Cl)	250	1000	8
Sulphate(as SO ₄)	200	400	----
Nitrate as(NO ₃)	45	45	4
Fluoride	1.0	1.5	0.1
Total Dissolved Solids	500	2000	32
Iron	1.0	No Relaxation	----
Residual Chlorine	0.2	1.0	----

Remarks : Water is Potable (P)/Unpotable (U)


Superintending Chemist
Public Health Engineering Department
Jodhpur

No.Lab./Tech.(chem)/2024-25/

Copy To :

1. Chief Chemist, State Laboratory Gandhi Nagar, Jaipur

Superintending Chemist
PHED Laboratory, Jodhpur